



## BASIC BACTERIA WATER TEST

1234 Main St. Weaverville NC 28787

Buyer Name

01/04/2022 9:00AM



Inspector

**JAMES B**

NC Septic Inspector 5829I and Septic  
Installer Level II #5829

828.552.5174

lab@wncil.com



Agent

**Agent Name**

555-555-5555

agent@spectora.com

# 1: TEST INFORMATION

## Information

---

**Sample ID**

WNCIL-2021-2166

**Type of Test**

Basic Bacteria

**Collected By**

CT ID# NC-0117

**Collected Date**

2021-12-31

**Where was sample collected**

Pressure System

**Water Source**

Well

**Customer Name**

Ronald Autrey

**Customer Relationship to Property**

Owner

**Report Date**

2022-01-03

## 2: BASIC BACTERIA RESULTS

		Pass	Fail	N/A	Other
2.1	Total Coliform	X			
2.2	E. Coli	X			

Pass = Pass    Fail = Fail    N/A = No Recommended Level    Other = Other

### Information

#### Basic Bacteria Information

Total Coliform is a family of bacteria and E. coli is a specific type of Coliform (like humans are a specific type of mammal). The EPA says that any amount of Total Coliform or E. coli means the water source should be treated; therefore, the test used by most labs in the country, including the NC State Lab of Public Health, is an Absent/Present test (no count is given).

#### Total Coliform: Total Coliform

Absent (Pass)

#### E. Coli: E. Coli

Absent (Pass)